

CITY OF SPRINGFIELD
INTER-OFFICE MEMORANDUM

ATTENTION OF _____ FILE _____

DATE September 21, 1981

DEPARTMENT _____

On Friday morning, September 18, 1981, Bob Corson, Steve Short and I performed a smoke test at manhole #12 on south Campbell Street in order to test the unused lateral line that was allowing sewer gas to enter on 401 W. McDaniel. (the lateral line had been filled full of grout by the owner of Indiv in an effort to seal off the line.) Smoke filled the basement of Royal Plastic Printers on 310 S. Campbell, but no smoke entered the basement of Indiv.

300 S. CAMPBELL

Karen Chandler

Karen Chandler
Water Pollution Control Inspector I
SIGNED Surveillance & Enforcement